


Long Radius 90° Elbows

STANDARD WEIGHT

Inches / Pounds



Nominal Pipe Size	Outside Diameter	Inside Diameter	Wall Thickness (T)	Center To End (A)	Pipe Schedule	Weight In Pounds
1/2	0.84	.622	.109	1.50	40	0.16
3/4	1.05	.824	.113	1.50	40	0.17
1	1.32	1.049	.133	1.50	40	0.40
1 1/4	1.66	1.38	.140	1.88	40	0.55
1 1/2	1.90	1.61	.145	2.25	40	0.8
2	2.38	2.07	.154	3.00	40	1.6
2 1/2	2.88	2.47	.203	3.75	40	3.2
3	3.50	3.07	.216	4.50	40	4.8
3 1/2	4.00	3.55	.226	5.25	40	6.6
4	4.50	4.03	.237	6.00	40	8.9
5	5.56	5.05	.258	7.50	40	15.1
6	6.62	6.07	.280	9.00	40	24
8	8.62	7.98	.322	12.00	40	47.8
10	10.75	10.02	.365	15.00	40	83.4
12	12.75	12.00	.375	18.00	*	123
14	14.00	13.25	.375	21.00	30	155
16	16.00	15.25	.375	24.00	30	206
18	18.00	17.25	.375	27.00	*	262
20	20.00	19.25	.375	30.00	20	324
24	24.00	23.25	.375	36.00	20	466
30	30.00	29.25	.375	45.00	*	720
36	36.00	35.25	.375	54.00	*	1,039
42	42.00	41.25	.375	63.00	*	1,420
48	48.00	47.25	.375	72.00	*	2,000

* This Size and thickness does not correspond to any pipe schedule number.

1. Dimensions conform to ASME B16.9 & material conforms to ASTM A-234 Grade B
 2. For bevel detail see Weld End Bevel Detail.
 3. For dimensional tolerances see Weld Fitting Dimensional Tolerances.